

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-1591:152

Page 1 of 1

**CATEGORY:** Audible Devices

**LISTEE:** Edwards Systems Technology, 6411 Parkland Drive, Sarasota, FL 34243  
Contact: Leon Newsome (941) 739-4276 Fax (941) 739-4334

**DESIGN:** Models 2447, 781, 782, 860, 862, 864, 866, 880 through 887, 892, 894, 897, 981, 982 horns and Models 791, 792, 792-5, 792-7, 792-8, 891, 892B, 895, 991, 992, 2452-H and 2452-M horn/strobes.

Units may be followed by suffix A through Z and additional suffix to designate color. Refer to listee's data sheet for detailed product description and operational considerations.

**INSTALLATION:** In accordance with the listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as audible and audible/visual signaling devices for use with separately listed compatible control units. Models 792-5, 792-7, 792-8, 2452-H and 2452-M are suitable for hearing impaired application. Horns and Horns/Strobes are suitable for outdoor use when equipped with back box No. 897B-007.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Formerly 7135-0073:123, 7135-1388:124

11-02-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager